

Sr. No.	Genset Rated →	160kVA - Mech	160kVA - CRDI
A	Genset specification ↓		
1	Genset rating	Prime	Prime
2	Genset output (kVA/kWe)	160 / 128	160 / 128
3	Genset model	GPWII-PIV-160M	GPWII-PIV-160C
4	Gross engine Power (kWm)	144.5	144.5
5	Gross engine Power (HP)	196.6	196.6
6	Engine model	6G11TAG32	6G11TAG44
7	Aspiration / Cooling	TCAC	TCAC
8	No. of Cylinders / Arrangement	6 / inline	6 / inline
9	Displacement (L)	7.31	7.31
10	Bore x Stroke (mm)	108 X 133	108 X 133
11	Compression ratio	16.8	16.8
12	Rated RPM	1500	1500
13	Overspeed trip (RPM)	1650	1650
14	Governor type / DG Performance Class	Elec / G3	CRS / G3
15	Frequency Regulation	Isochronous	Isochronous
16	Air cleaner type / Qty	Dry / 01	Dry / 01
B	Exhaust system		
1	Max allowable backpressure (kPa)	13	13
2	Exhaust temperature (Deg C)	525	525
3	Silencer type	NA	NA
4	Aftertreatment System	DOC+SCR+ASC	DOC+SCR+ASC
C	Engine electrical system		
1	Charging alternator VDC / Amps	12 V / 35 A	12 V / 35 A
2	Starter motor rated voltage (DC)	12	12
3	Battery voltage (DC) / Capacity (AH)	12V / 130 AH	12V / 130 AH
D	Fuel System		
1	Recommended fuel	IS 1460, HSD	IS 1460, HSD
2	Fuel tank capacity (L)	260	260
E	Fuel Consumption @ % load (LPH)(Including radiator fan + other accessories)⁽¹⁾		
1	LPH @ 100%	34.50	33.50
2	LPH @ 75%	26.20	25.20
F	Lubricating Oil System		
1	Lube oil sump capacity (L)	17.5	17.5
2	Lube oil change period (Hrs)	500	500
3	Lube oil consumption (% of SFC)	≤0.06%	≤0.06%
4	Lube oil filter type / Qty	Spin on / 01	Spin on / 01
5	Recommended lube oil grade	15W40, API CI4+	15W40, API CI4+
6	Recommended lube oil	Greaves Maxtherm	Greaves Maxtherm

EXPRESS ENGINEERS AND SPARES PRIVATE LIMITED

Email ID: expeng@generatorbazar.com Website: www.generatorbazar.in

Registered Office: 83, Rajdhani Nikunj, 94, I. P. Extension, Patpar Ganj, Delhi -110092, India

Corporate Office: A-18 Rampuri, Surya Nagar Market, Ghaziabad, Uttar Pradesh - 201011

Tel: +91 0120 4100100, 4377077, 9212757575, 9810885060

G	Alternator Specification		
1	Alternator Make	LS	LS
2	Voltage (3P)	415	415
3	Frequency (Hz)	50	50
4	Current (3P) (Amps)	222.4	222.4
5	Type	4P, rotating field	4P, rotating field
6	Voltage regulator	Automatic	Automatic
7	Voltage regulation -%	±1%	±1%
8	Insulation class	H	H
9	Temperature rise (Deg C)	125	125
10	Bearing (Qty / type)	1, sealed	1, sealed
11	Coupling	Flex disc	Flex disc
12	Unbalanced load capability	25% of rated amps	25% of rated amps
H	Cooling System		
1	Max ambient capability (Deg C)	50	50
2	Coolant capacity (Eng + Rad) (L)	35	35
I	Controller		
1	Controller Model	DSE 6120 MKIII	DSE 6120 MKIII
J	DEF System		
1	Recommended fuel	ISO 22241, DIN-70070	ISO 22241, DIN-70070
2	DEF Tank Capacity (L)	40	40
K	DEF Consumption		
1	LPH @ 100%	1.7	1.7
2	LPH @ 75%	1.3	1.3
L	Genset Outer Dimensions		
1	Length(L) X Width(W) X Height(H) (mm)	4020 x 1500 x 2300	4020 x 1500 x 2300
2	Dry Weight (Approx.) (kg)	2210	2210
	Disclaimer:		
	- Ref.: ⁽¹⁾Fuel consumption @ 0.85 Specific Gravity with 5% Tolerance, DEF consumption : 5% of FC - PRIME POWER RATING as per ISO 8528 - Conformance standards: Engine - BS 5514, ISO 3046, Alternator - IS 13364 (Part - II), Genset - ISO 8528 and Tolerances as applicable. Please refer our GA drawing for overall dimension with add on components like silencer, ducts etc. - Product specifications are subject to change without prior notice due to the policy of continuous improvement. - Others make alternator also available – Please consult application engineering department		

EXPRESS ENGINEERS AND SPARES PRIVATE LIMITED

Email ID: expeng@generatorbazar.com Website: www.generatorbazar.in

Registered Office: 83, Rajdhani Nikunj, 94, I. P. Extension, Patpar Ganj, Delhi -110092, India

Corporate Office: A-18 Rampuri, Surya Nagar Market, Ghaziabad, Uttar Pradesh - 201011

Tel: +91 0120 4100100, 4377077, 9212757575, 9810885060