



Sr. No.	Genset Rated →	320kVA - CRDI
Α	Genset specification $igstarrow$	
1	Genset rating	Prime
2	Genset output (kVA/kWe)	320 / 256
3	Genset model	GPWII-PIV-320C
4	Gross engine Power (kWm)	284
5	Gross engine Power (HP)	386.4
6	Engine model	D3V6TAG41
7	Aspiration / Cooling	TCAC
8	No. of Cylinders / Arrangement	6 / V-Type
9	Displacement (L)	10.04
10	Bore x Stroke (mm)	128 X 130
11	Compression ratio	16.8
12	Rated RPM	1500
13	Overspeed trip (RPM)	1650
14	Governor type / DG Perfomance Class	CRS / G3
15	Frequency Regulation	Isochronous
16	Air cleaner type / Qty	Dry / 01
В	Exhaust system	
1	Max allowable backpressure (kPa)	20
2	Exhaust temperature ( Deg C)	550
3	Silencer type	NA
4	Aftertreatment System	DOC+SCR+ASC
С	Engine electrical system	
1	Charging alternator VDC / Amps	24 V / 35 A
2	Starter motor rated voltage (DC)	24
3	Battery voltage (DC) / Capacity (AH)	12V / 180 AH X 2
D	Fuel System	
1	Recommended fuel	IS 1460, HSD
2	Fuel tank capacity (L)	520
E	Fuel Consumption @ % load (LPH)(Including radiator fan + other accessories) <sup>(1)</sup>	
1	LPH @ 100%	70.50
2	LPH @ 75%	52.30
F	Lubricating Oil System	
1	Lube oil sump capacity (L)	30
2	Lube oil change period (Hrs)	500
3	Lube oil consumption (% of SFC)	≤0.06%
4	Lube oil filter type / Qty	Spin on / 02
5	Recommended lube oil grade	15W40, API CI4+
6	Recommended lube oil	Greaves Maxtherm

EXPRESS ENGINEERS AND SPARES PRIVATE LIMITED

Email ID: expeng@generatorbazar.com Website: www.generatorbazar.in Registered Office: 83, Rajdhani Nikunj, 94, I. P. Extension, Patpar Ganj, Delhi -110092, India Corporate Office: A-18 Rampuri, Surya Nagar Market, Ghaziabad, Uttar Pradesh - 201011 Tel: +91 0120 4100100, 4377077, 9212757575, 9810885060



## GREAVES

G	Alternator Specification	
1	Alternator Make	MECCALTE
2	Voltage (3P)	415
3	Frequency (Hz)	50
4	Current (3P) (Amps)	445.18
5	Туре	4P, rotating field
6	Voltage regulator	Automatic
7	Voltage regulation -%	±1%
8	Insulation class	Н
9	Temperature rise (Deg C)	125
10	Bearing (Qty / type)	1, sealed
11	Coupling	Flex disc
12	Unbalanced load capability	25% of rated amps
Н	Cooling System	
1	Max ambient capability (Deg C)	50
2	Coolant capacity (Eng + Rad) (L)	100
l.	Controller	
1	Controller Model	DSE 6120 MKIII
J	DEF System	
1	Recommended fuel	ISO 22241, DIN- 70070
2	DEF Tank Capacity (L)	60
K	DEF Consumption	
1	LPH @ 100%	3.5
2	LPH @ 75%	2.6
L	Genset Outer Dimensions	
1	Length(L) X Width(W) X Height(H) (mm)	5030 x 1950 x 2480
2	Dry Weight (Approx.) (kg)	4150
	Disclaimer:	
	<ol> <li>Ref.: <sup>(1)</sup>Fuel consumptioin @ 0.85 Specific Gravity with 5% Tolerance, DEF consumption : 5% of FC</li> <li>PRIME POWER RATING as per ISO 8528         <ol> <li>Conformance standards: Engine - BS 5514, ISO 3046, Alternator - IS 13364 (Part - II), Genset - ISO 8528 and Tolerances as applicable. Please refer our GA drawing for overall dimension with add on components like silencer, ducts etc.</li> <li>Product specifications are subject to change without prior notice due to the policy of continuous improvement.</li> <li>Others make alternator also available – Please consult application engineering department</li> </ol> </li> </ol>	

EXPRESS ENGINEERS AND SPARES PRIVATE LIMITED Email ID: expeng@generatorbazar.com Website: www.generatorbazar.in Registered Office: 83, Rajdhani Nikunj, 94, I. P. Extension, Patpar Ganj, Delhi -110092, India Corporate Office: A-18 Rampuri, Surya Nagar Market, Ghaziabad, Uttar Pradesh - 201011 Tel: +91 0120 4100100, 4377077, 9212757575, 9810885060